Calculation and Selection - Differential Pressure Controller

Initial data

10.00 m3/h	Estimated water flow rate	6.00 bar	Pressure before controller
100 °C	Maximum water temperature at the installation place	0.50 bar	Allowable pressure loss across controller
		0.50 bar	Differential pressure to maintain

Calculation results

[10.00 m3/h] / [0.50 bar]^0.5 = 14.14 [m3/h]	Required Kv value
0.00000005 * [100 °C]^3.658 = 1.04 [bar]	Absolute saturation vapor pressure of water at temperature $100^{\circ}C$
0.2*(6.00+1-1.04) = 1.19 [bar]	Lower limit without cavitation pressure loss at the controller
0.6*(6.00+1-1.04) = 3.58 [bar]	Upper limit without cavitation pressure loss at the controller
0.50 [bar] <= 1.19 [bar]	There will be no cavitation on the controller
([G 10.00 m3/h] / [Kvs 21 m3/h])^2 = 0.23 [bar]	Pressure drop across a fully open controller with Kvs=21 [m3/h] with flow rate 10.00 [m3/h]
[10.00 m3/h] / {3600 *3.14 *([DN40] *0.001)^2 *0.25} = = 2.2 [m/s]	The flow rate is within normal limits $V < 3.0[m/s]$

Selection result : Differential pressure controller

LDM : RD 122 D

Czechia

maintains the set pressure drop

normally open

- DN 40 [mm] Nominal controller diameter
- Kvs 21 [m3/h] Flow coefficient

PN 25 [bar] Nominal pressure

dP 0.15...0.60 [bar] Pressure setting range

dT 2 ... 150°C Operating temperature

cast iron Body material

67 % The percentage of the opening of the controller gate at which Kv=14.14 [m3/h], and the pressure loss on the controller will be 0.50 [bar] when passing the calculated flow rate 10.00 [m3/h]

