

Vitocell 140-E, Vitocell 160-E

Applicable for type:

SEIB

SEIA

We, Viessmann Limited, Hortonwood 30, Telford TF1 7YP, United Kingdom, declare as authorised representative of the manufacturer and in sole responsibility for the manufacturer, that the named product complies with the provisions of the following directives and regulations.

Pressure Equipment (Safety) Regulations 2016

Details in accordance with the Pressure Equipment (Safety) Regulations 2016:

- Heated pressure vessel (not at risk from overheating)
- DHW an heating water section according to Article 4, section (3)
- Modules B and C2 in accordance with appendix III
- Materials according to AD 2000 regulations in accordance with assessment and appendix I, 4.2, b)
- Corrosion supplement in accordance with appendix I, 2.2 and AD 2000 regulations

The pressure vessel was tested without fitted equipment (safety equipment). It must be equipped in accordance with national regulations before installation and commissioning.

Applied standards:

DIN 4753-7:2019

EN 12897:2016

In accordance with the specified directives, this product is designated with 

Telford, 21.02.2023

Viessmann Ltd



Christian Engelke
Technical Director

Viessmann Limited
Hortonwood 30, Telford
Shropshire, TF1 7YP, GB
Telephone: +44 1952 675000
Fax: +44 1952 675040
E-mail: info-uk@viessmann.com

4750002598