

Danfoss A/S

6430 Nordborg Denmark CVR nr.: 20 16 57 15

Telephone: +45 7488 2222 Fax: +45 7449 0949

EU DECLARATION OF CONFORMITY

Danfoss A/S Danfoss DEN Controls

declares under our sole responsibility that the

Product category: Control Valves

Type designation(s):

MEV	VB 2	VF 2/3	VFG 2/21
VFG 22	VFG 221	VFG 33	VFGS 2
VFM 2	VFQ 2	VFS 2	VFU 2/21
VG(F)	VGU(F)	VM 2	

PN(PS)	DN <=32	DN 40	DN 50	DN 65	DN 80	DN 100	DN 125	DN 150	DN 200	DN 250	DN 300	DN 350	DN 400	DN 450	DN 500	DN 600
6	Art. 4 §3	Cat. I	Cat. I	Cat. I	Cat. I	Cat. I	Cat. I	Cat. I	Cat. II							
10	Art. 4 §3	Cat. I	Cat. I	Cat. I	Cat. I	Cat. I	Cat. I	Cat. II	Cat. II	Cat. II	Cat. III					
16	Art. 4 §3	Art. 4 §3	Art. 4 §3	Cat. I	Cat. I	Cat. II	Cat. II	Cat. III								
25	Art. 4 §3	Art. 4 §3	Cat. I	Cat. II	Cat. II	Cat. II	Cat. III									
40	Art. 4 §3	Cat. I	Cat. II	Cat. II	Cat. II	Cat. II	Cat. III									

Covered by this declaration is in conformity with the following directive(s), regulation(s), standard(s) or other normative document(s), provided that the product is used in accordance with our instructions.

This doc. is managed by 500B0577



Pressure Equipment Directive 2014/68/EU

• EN 12266-1:2012 Industrial valves - Testing of metallic valves - Part 1: Pressure tests, test procedures and acceptance criteria - Mandatory

requirements

• EN 12516-2:2014 + Industrial valves - Shell design strength - Part 2: Calculation method for steel valve shells

Conformity assessment procedure according to Module H - Full quality assurance. A risk assessment has been performed and documented according to Annex I.

Products belonging to Art. 4.3 are not marked.

Products in categories I, II, and III are marked with CE 0062 and evaluated by: Bureau Veritas Services SAS, 8 Cours du Triangle, 92800 Puteaux - La Défense - France

Certificate issued: N° CE-0062-PED-H-DAF 001-21-DNK-rev-A



Danfoss only vouches for the correctness of the English version of this document. In the event of the document being translated into any other language, the translator concerned must be liable for the correctness of the translation.